

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

14-October-2022

Peacock Point Cottage Owners Association

Attn : Marc Vallee

Date Rec. : 12 October 2022
 LR Report: CA20572-OCT22

7 Barbara Drive
 Nanticoke, ON
 NOA 1L0,

Copy: #1

Phone: 226-931-1952
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL
1: Analysis Start Date		---	---	12-Oct-22	12-Oct-22
2: Analysis Start Time		---	---	16:15	16:15
3: Analysis Completed Date		---	---	14-Oct-22	14-Oct-22
4: Analysis Completed Time		---	---	16:30	16:30
5: MAC		---	---	0	0
6: DW Point of Entry	11-Oct-22 09:00	15.8	0.78	0	0

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety