

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

25-May-2023

**Peacock Point Cottage Owners Association**

Attn : Marc Vallee

Date Rec. : 17 May 2023  
 LR Report: CA21026-MAY23

7 Barbara Drive  
 Nanticoke, ON  
 NOA 1L0,

Copy: #1

Phone: 226-931-1952  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL
1: Analysis Start Date		---	---	17-May-23	17-May-23
2: Analysis Start Time		---	---	14:45	14:45
3: Analysis Completed Date		---	---	19-May-23	19-May-23
4: Analysis Completed Time		---	---	16:57	16:57
5: MAC		---	---	0	0
6: DW Point of Entry	16-May-23 09:00	13.3	0.69	0	0

MAC - Maximum Acceptable Concentration

#### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety